

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013704.03-R4
DATE: 03/13/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Seves Glass
CODE: 2322-1
REVISION DATE: 01/08/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Seves Glass Block s.r.o. Bilinská 782/42 Duchcov, 419 01, Czech Republic	“Residential Hurricane Resistant Windows w/Thickset 90 Series Glass Block & ProVantage Silicone System” Configuration: O Glazing: 3.88" Thickset® 90 Glass Block Panels Frame: W-1207mm (47.5") H-1207mm (47.5") Block Size: W-203mm(8") H-203mm(8")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±4800 Pa (100 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: 01-44639.03
Expiration Date: March 31, 2025

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023