

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013704.04  
**DATE:** 03/13/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Seves Glass  
**CODE:** 2322-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Seves Glass Block, Inc.</b> <b>10576 Broadview Road</b> <b>Broadview Heights, OH 44147</b>	<b>"Residential Hurricane Resistant Windows w/Thickset 90 Series Glass Block &amp; ProVantage Silicone System"</b>  Configuration: O Glazing: 3.88" Thickset® 90 Glass Block Panels  Frame: W-1807mm (71.13") H-1807mm (71.13") Block Size: W-203mm(8") H-203mm(8")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3256 Pa (68 psf) Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 44639.05-109-18  
Expiration Date: March 31, 2022

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122